

KNX

## KNX/DALI Gateway/Twin

N 141/14, N141/32



**The KNX/DALI Gateways are used for lighting control in buildings.**

- Up to 128 fully-fledged DALI channels for individual control of max. 128 DALI lights with automatic group creation
- For color temperature (Tunable White) and color control RGB(W) of DALI Device Type 8 lights according to Part 209 for the realization of e.g. Human Centric Lighting (HCL) applications
- Supports DALI-2 presence (Part 303) and brightness sensors (Part 304)
- IP interface for faster downloads
- Energy-saving function through the provision of up to 32 standby areas
- Integrated 2-point brightness and constant light controllers for easy implementation of complex light controls
- Customary simple commissioning process to increase efficiency



The KNX/DALI Gateways are used to control electronic control gear (ECG) and other DALI operating devices in lighting systems. They are used in building automation. Device control is performed via DALI on the lighting side and via KNX on the building automation side.

The KNX/DALI Gateways have one (N 141/14) or two (N 141/32) DALI outputs. A maximum of 64 fully fledged DALI channels and an additional 8 DALI-2 brightness and 8 DALI-2 presence sensors can be integrated for each DALI output. A maximum of 64 ECG can be controlled individually or in groups via the 64 DALI channels. For individual control, only one ECG is assigned to a channel. Group control is facilitated by the intelligent channel concept. This is because a DALI group is automatically created as soon as more than one ECG is assigned to a channel. This means that you do not have to specify in advance which ECGs are to be controlled individually or in groups. This allows for easier configuration. For complex lighting projects, it is thus possible to implement up to 32 groups per DALI output without going to the effort of linking group addresses.

The devices certified according to DALI-2 are multi-master application controllers and support the DALI-2 brightness and presence sensors as input devices in instance mode. For lighting control, it is possible to control not only the color temperature (Tunable White), but also the color (RGB, RGBW, HSV, HSVW) itself of type 8 DALI lights in line with IEC 62386-209. The ability to define up to 16 scenes per DALI output offers full flexibility for sophisticated automated lighting solutions. Integrated two-point lighting controllers as well as constant lighting controllers and max. 16 calculators for brightness values round off the package.

In order to do justice to the topic of sustainability, the KNX/DALI Gateways offer up to 16 standby areas per DALI output. This means that the power consumption of switched-off DALI-ECG can be significantly reduced via an intermediate switching actuator.

Each individual channel offers many other interesting functions and setting options, including four different operating modes, such as normal mode or timer mode, operating and switching cycle counters to maximize the availability of integrated lamps, 2 logic blocks, 7 priority override levels, separate on and off delays, day/night mode as well as a variety of status messages for monitoring.

Thanks to the clear and simple menu navigation in the integrated device control app (DCA), simple and efficient commissioning, both online and offline, is possible. In the DCA, the status of all connected lights can be viewed at a glance. It also offers a wide range of test options.

The KNX/DALI Gateways have a direct operating level at the front of the device. A membrane keypad with two control buttons keys and one status LED per DALI line can be used to centrally switch and dim all the lights connected to the DALI line (broadcast). This allows an uncomplicated light test without prior configuration and commissioning of the KNX/DALI Gateway. Potential errors (e.g. overload or short circuit) in the system are displayed down to the individual ECG level directly via the display and the LEDs of the membrane keyboard, and also via corresponding communication objects on the KNX bus. An efficient error analysis and search is thus guaranteed.

The KNX/DALI Gateways are rail-mounted devices in N dimension for installation in arrangements and installation on 35-mm DIN rails as per standard IEC 60715. The devices are connected to the bus via a bus terminal block. The electronics of the device are powered via the 230V supply voltage. Since the necessary voltage is thus provided for the DALI lines, no further external DALI voltage supply is required. In addition, it is not permitted to connect another DALI power supply. The maintenance-free terminals are for connecting solid and fine-stranded conductors with conductor cross-sections from 0.5 to 2.5 mm<sup>2</sup> or for connecting multi-stranded conductors with 2.5 mm<sup>2</sup> conductor cross-sections to the DALI outputs. Stranded and fine-stranded conductors can be plugged into the terminals without ferrules. The KNX/DALI Gateways N 141/14 and N 141/32 consist of the device (hardware), the application program (software), and the device control app (app).



## Functions of the KNX/DALI Gateway

### What is DALI?

DALI (Digital Addressable Lighting Interface) is a bi-directional communication interface as per IEC 62386, the specification of which was defined by manufacturers for electronic control gear (ECG). It enables reception of e.g. switching and dimming commands as well as transmission of status information, such as the failure of a lamp or reporting an error in the ECG.

A DALI bus line can be used to connect up to 64 DALI actuators as well as 8 brightness and 8 presence sensors or multisensors, each of which can be assigned an individual participant address. This makes it possible to control each device individually, and status and error messages can be assigned to a specific electronic control device and therefore to a specific lamp. The KNX/DALI Gateway N 141/14 or N 141/32, for example, can be used for the individual control of DALI devices.

For more information on DALI, visit: <http://www.dali-alliance.org>. The DALI dimming curve has been adapted to the sensitivity of the human eye. This results in a logarithmic characteristic curve for the luminous flux. However, humans perceive this logarithmic characteristic curve as a linear brightness curve. IEC 62386-102 describes the DALI values as "ARC Power across the light source," with an almost linear correlation to the luminous flux in most cases. The luminous flux describes the entire power emitted by a light source in all directions. The unit is lumen (lm).

### Basic information about the KNX/DALI gateway N141/14 or N 141/32

The device is used to control DALI electronic control gear (ECG) via commands. Depending on the selected operating mode, in addition to the communication objects for the functions switching, dimming brighter/darker, dimming value, color temperature and status requests, there is a series of additional functions available for each output, line or channel. As an alternative to the switching input, a control value input with configurable threshold value for switching on and off can be selected. In direct operation, a line can be operated via the corresponding push-buttons on the user interface. The device display shows the error codes of the DALI channel error messages. A corresponding communication object is created for each error message.

These KNX/DALI Gateways are KNX devices with one or two independent DALI interface(s), to which up to 64 DALI ECGs and an additional 8 DALI brightness and 8 DALI motion sensors are connected per line (8 combined brightness and motion sensors per DALI line are also possible). These can be controlled individually or in groups using the device. In addition, the device can detect and transmit status and error messages from DALI devices. To ensure efficient and fast commissioning, the device offers its own IP interface. The device can control both the brightness of the lights and also the color temperature ("Tunable White") and light color ("RGB(W)"). The device can therefore be used in human-centric lighting applications.

Individual names, parameters and scenes are assigned to the individual ECGs by means of ETS (Engineering Tool Software). The DALI sensors and their functionality are also assigned in the ETS. All DALI participants and functions are independent and can be linked via group addresses. The device is designed to act as the only multi-master application controller in a DALI segment. Other application controllers are switched off during configuration. The KNX/DALI Gateway is a rail-mounted device for installation in distributions. For DALI, the electronics of the DALI devices are fed via the DALI bus line. Hence, the device has an integrated power supply for AC 230 V for supplying the device electronics and generating the DALI bus voltage for each line.

All functions of the KNX/DALI Gateway are briefly described below.

### Line operating modes

Each output (line) of the KNX/DALI Gateway can be set to one of the following operating modes:

- Normal mode (bus)
- Broadcast
- Deactivated



### **Normal mode**

In normal mode, ECGs in channels can be switched and dimmed individually without restriction. Control is carried out for each channel by three communication objects (switching, dimming, value setting). A channel assignment of an ECG can only be made to a maximum of one DALI channel. Multi-channel assignments are not directly supported. If necessary, the assignments must be implemented via the KNX communication objects or via ECG control. Separate status objects inform about the switching and value status of the channel.

### **Broadcast**

The "Broadcast" DALI line operating mode allows the simultaneous control of all connected ECGs in the channels via the broadcast commands provided by DALI. Sensors are not taken into account. Commissioning is significantly reduced because neither the search nor the individual assignment is necessary. Thus, all settings for ECG, channels and sensors, the commissioning and test functionality for this line are omitted. For configuration, the parameters are available as in a group (ignition time 0.7s).

### **Deactivated**

If a DALI line is deactivated, no channels attached to it and no assigned ECGs can be addressed.

### **Channel operating modes**

Each channel of the KNX/DALI Gateway can be set to one of the following operating modes:

- Normal mode
- Timer mode
- Timer mode 2-fold
- Flashing
- Deactivated

### **Normal mode**

In normal mode, ECGs in channels can be switched and dimmed individually without restriction. Control is carried out for each channel by three communication objects (switching, dimming, value setting). A channel assignment of an ECG can only be made to a maximum of one DALI channel. Multi-channel assignments are not directly supported. If necessary, the assignments must be implemented via the KNX communication objects or via ECG control. Separate status objects inform about the switching and value status of the channel.

### **Timer mode**

In the "normal mode" operating mode, the timer modes for "delayed switching on and off" and "timer night mode" are available. For night mode, an additional warning can be set before switching off. In the "timer mode" operating mode, the functions "ON time 1 in day mode" and "ON time in night mode" are available. Moreover, a warning before switching off can be set separately for both functions. In the "timer mode 2-fold" operating mode, the functions "ON time 1 in day mode" and "ON time 2 in day mode" and "ON time in night mode" are available.

### **Flashing**

In the "Flashing" operating mode, the channel is switched on and off cyclically with an adjustable on and off duration. It is also possible to set up delayed switching on and off.

### **Deactivated**

If a channel is deactivated, no assigned ECGs can be addressed.



### Overrides:

Up to seven different override function blocks can be activated to override the automation functions. For each override function block, one of the following functions can be selected:

- Manual override (ON)
- Permanent OFF
- Lock
- Central Override
- User-defined override function
- Forced Control

This enables flexible configuration of a separate priority-specific override for each channel. For the override functions a control value input can be selected instead of a switching input.

### Counting of switching cycles and operating hours:

The application program features optional counting of switching cycles and counting of operating hours without threshold monitoring for each channel.

### Scenes

The application program makes it possible to parameterize up to 16 scenes per DALI line. Up to 64 channels can be added to each scene. The dimming and color temperature values for the scene can be specified for each channel. As an alternative to the color temperature values, color values can be specified. The scenes are stored and retrieved via an 8-bit communication object. When new scene values are saved, the value of the channels is not queried via DALI; instead the internally calculated value is used. This value is then written to the channels and the associated ECG.

### Logic operations

The KNX/DALI Gateway has 2 independent logic blocks per channel with which different mathematical operations are possible: AND, OR, XOR, FILTER, TRIGGER. The switching information for the second input of logic operation 1 or 2 is received at the output via a corresponding communication object. The logic result is sent via a KNX communication object.

### Color temperature control

The color temperature control is defined in standard DALI IEC 62386, in chapter 209 "Color Control." The ECG is defined as device type 8. Device type 8 refers to color controllable lights. The unit for color temperature is Kelvin (K). The KNX/DALI gateways N 141/14 and N 141/32 can control the color temperature and brightness of type 8 ECG devices. The devices can be used in human-centric lighting applications, as it can control the color temperature of a DALI LED from warm white to cold white ("Tunable White"). Human-centric lighting (HCL) expands the concept of biologically effective lighting with holistic planning and covers the visual, emotional and biological effects of light. HCL supports human health, well-being and performance in the long-term.

### Color control

In the KNX/DALI Gateway, DALI control devices of the type "DT8 - Colour Control" can be used to control the light color. An RGB(W) color control allows precise control of LED lights that combine red, green, blue and white (RGBW). This control offers a wide range of color options and makes it possible to generate both colored light and pure white light. The HSV color control describes colors in a cylindrical color model and offers an intuitive way of color control.

### Ethernet

The KNX/DALI Gateways have an RJ45 socket via which the device can be connected to Ethernet. This significantly shortens the download times of the firmware and configuration.

### 2-point brightness controller

Up to 16 independent switching brightness controllers (2-point-lighting controls) are provided. These are independent of all other functions and can be used via objects.



2-point control is the most basic form of lighting control. If the brightness controller is activated (automatic operation), the lighting is switched on as soon as the brightness falls below the configured lower brightness limit. The lighting is switched off once the configured upper brightness limit is exceeded. The brightness limits can be set using parameters or communication objects.

### **Constant lighting control**

Up to 16 independent steadily regulating constant light controllers are provided. These are independent of all other functions and can be connected and used via objects both internally and externally.

Constant lighting control is an advanced form of lighting control. The control uses natural light to balance out the artificial light that is necessary to light the room adequately, which reduces power consumption and therefore costs. The illuminance of natural light entering a room through the window decreases the deeper it enters into the room. The controller is able to control one main lamp group and up to four subsidiary lamp groups. This is especially suitable for application in rooms in which the daylight entering through the window decreases further into the room.






Fig. 1: new channel concept

The new generation of DALI-2 certified KNX/DALI gateways N 141/14 and N 141/32 is equipped with up to two separate DALI outputs (A and B), depending on the version. The line (A or B) forms the top-level DALI instance, which can be connected to up to 64 ECGs and additional sensors. Within the DALI line, up to 64 ECGs are assigned to the respective provided smart channels, of which there are also up to 64. Among other things, the intelligence of the channels ensures that, if more than one ECG is assigned per channel, a DALI group is automatically created from the ECGs assigned to the channel. In addition, the channels containing the most ECGs are given preference when groups are created (i.e. group 1 = channel xy with the highest number of ECGs, group 2 = channel yx with the second-highest number of ECGs). The advantage of this functionality especially comes into effect if there are more than 16 channels with more than one ECG and there is thus the need for more than the 16 groups provided by DALI. From group 17 onwards, the ECGs are actuated in the KNX/DALI gateway directly via the channels as if they were a group, even though sequential control runs in the background. Controlling an individual ECG is still easily possible in the new KNX/DALI gateways if only one ECG is assigned to a channel. DALI-2 sensors are incorporated at the line level.

## Programming mode




Fig. 2: Programming button and programming LED (exemplary illustration)



After bus voltage recovery, wait several seconds before pushing the programming (1) button (not before booting is complete).



### Activate programming mode

- ◆ Briefly press the programming button (1) (< 2 seconds).
- ⇒ Programming mode is activated.
- ⇒ The programming LED (1) illuminates continuously.

### Deactivating programming mode

- ✓ Programming mode is activated. The programming LED (1) illuminates continuously.
- ◆ Briefly press the programming button (1) (< 2 seconds).
- ⇒ Programming mode is deactivated.
- ⇒ The programming LED (1) is not illuminated.

### Resetting the device to factory settings

NOTICE	
!	<b>Loss of data due to resetting device!</b> When you reset the device, all parameters and settings entered are deleted. <ul style="list-style-type: none"><li>● Ensure that the device is really supposed to be reset.</li></ul>

### Resetting the device to factory settings




Fig. 3: Programming button and programming LED (exemplary illustration)

- ◆ Press the programming push-button (1) (at least 20 seconds) until the programming LED (1) starts flashing quickly.
- ⇒ The programming (1) LED flashes for 8 seconds.
- ⇒ The device has been reset to factory settings. All parameter settings have been deleted.
- ⇒ The building site function is active again.

### Behavior on unloading the application program

After unloading the application program with the ETS, the unloaded device has no functions.

### Behavior on voltage failure/recovery

The electronics of the device are powered by mains power. A supply voltage failure leads to a functional failure of the KNX/DALI gateway.

In case of supply voltage failure, the current status and other values for each output are permanently saved so that they can be restored if applicable when the supply voltage is recovered.

On supply voltage recovery, the configured actions are executed and, if applicable, new status values are reported.



## Operation and error display on the device

The display on the front of the KNX/DALI Gateway shows whether there is an error and what type of error it is. The LEDs allow an exact localization of the error. The navigation on the display is done with the help of the arrow keys.




Fig. 4: KNX/DALI gateway - operation and error display on the device

### NOTICE



The parameter “Information on device display” can be used in the ETS to specify what is displayed on the display.

- Deactivated
- Operation
- Operating mode
- Firmware version

### Process

- If an error occurs, an error LED lights up [1]
- The error navigation on the display is done by pressing the arrow keys [2].
- The two LEDs [3] above the display indicate in which line the error occurs.

The following errors can occur:

Errors	Description
F0	Lamp defective
F1	ECG defective
F3	External voltage on DALI line
F5	DALI short circuit
F6	No ECG found
F7	Application controller switched off






Fig. 5: Operating and display elements

Item	Operating or display element	Function
1	Programming LED (red), Programming button	<p>Short push of button (&lt; 2 s):</p> <ul style="list-style-type: none"> <li>Activate programming mode, display status (LED on = active).</li> </ul> <p>Very long push of button (&gt; 20 s):</p> <ul style="list-style-type: none"> <li>Reset to factory settings (after 20 s, the LED starts flashing for about 8 s).</li> </ul> <p>Hint:</p> <ul style="list-style-type: none"> <li>A longer push of button (&gt;2 s to 20 s) does not perform any function.</li> <li>The device can be locked for programming mode for approx. 10 s. This is indicated by the flashing of the programming LED.</li> </ul>
2	Button: Deactivate direct operation	<p>Short press of button (&lt; 1 s):</p> <ul style="list-style-type: none"> <li>Deactivate/exit direct operation.</li> </ul>



Item	Operating or display element	Function
3	Status LED of direct operation	The LED shows whether direct operation is activated. The LED flashes regularly if direct operation is active for at least one channel.
4	Status LED of the IP connection	The LED shows if there is a link in the IP connection. The LED lights up when an Ethernet cable is connected and if communication is performed via IP.
5	Test contacts	Metering point for voltage testing
6	Buttons: Switching on line A or line B	Short press of button (< 1 s): <ul style="list-style-type: none"> <li>ECGs on line A/B are switched on (broadcast)</li> </ul> Long press of button (> 1 s): <ul style="list-style-type: none"> <li>ECGs on line A/B are dimmed brighter (broadcast).</li> </ul>
7	Error LEDs	The LEDs indicate whether there is an error on the respective line A or line B.
8	LEDs of the error display	The LEDs indicate the current line when the error display is operated with the buttons.
9	Button: Top	Menu control up in the display Hint: <ul style="list-style-type: none"> <li>If the button is not pressed for more than 5 seconds, the standard display returns automatically.</li> </ul>
10	Button: Bottom	Menu control down in the display Hint: <ul style="list-style-type: none"> <li>If the button is not pressed for more than 5 seconds, the standard display returns automatically.</li> </ul>
11	Button: Enter	Confirmation of the error Hint: <ul style="list-style-type: none"> <li>If the button is not pressed for more than 5 seconds, the standard display returns automatically.</li> </ul>
12	Display	The display is used to display the device information (status, error codes and currently loaded firmware version): Hint: The following device information can only be displayed if the "Information on device display" parameter is enabled. Status display: <ul style="list-style-type: none"> <li>d: Direct operation (manual operation)</li> <li>b: Normal operation (bus operation)</li> <li>...: Short address of the affected ECG</li> </ul> Error display: <ul style="list-style-type: none"> <li>F0: Lamp defective</li> <li>F1: ECG defective</li> <li>F3: External voltage on DALI line</li> <li>F5: DALI short circuit / overload</li> <li>F6: No ECG found</li> <li>F7: Application controller switched off</li> </ul> Display of the loaded firmware version
13	Buttons: Switching off line A or line B	Short press of button (< 1 s):



Item	Operating or display element	Function
		<ul style="list-style-type: none"> <li>ECGs on line A/B are switched off (broadcast)</li> </ul> Long press of button (> 1 s): <ul style="list-style-type: none"> <li>ECGs on line A/B are dimmed darker (broadcast)</li> </ul>

#### Position and function of the connections and labeling






Fig. 6: Connections

Item	Element	Function
1	Connection pins for KNX bus terminal block, screwless	Connect KNX bus
2	Label field	Enter physical address
3	Connection terminals	Connect input and loads
4	Connection terminals for DALI lines	Connecting DALI lines
5	Membrane keypad with LEDs	Execute direct operation Switching and dimming lights Displaying status and error messages
6	RJ45 connector socket	Connecting IP communication



## Type overview

Type	Designation	Item number
N 141/14 	KNX/DALI Gateway	5WG1141-1AB14
N 141/32 	KNX/DALI Gateway Twin	5WG1141-1AB32

## Version of the Engineering Tool Software

Application	Version
Engineering Tool Software (ETS)	ETS 5 or above Recommendation: ETS 6.3 or above

## Product documentation and support

### Product documentation

Documents related the product, such as operating and installation instructions, application program description, product database, additional software and CE declarations can be downloaded from the following website:

<http://www.siemens.com/gamma-td>



### Frequently asked questions

For frequently asked questions about the product and their solutions, see:

<https://support.industry.siemens.com/cs/products?dtp=Faq&mfn=ps&lc=en-WW>





## Support

Contact details for additional questions relating to the product:

Tel.: +49 89 9221-8000

<http://www.siemens.com/supportrequest>



## Notes

### Security

#### CAUTION



##### National safety regulations

Failure to comply with national safety regulations may result in personal injury and property damage.

- Observe national provisions and comply with the appropriate safety regulations.

#### WARNING



##### Risk of death due to electric voltage and electric current!

Electrical expertise is required for the installation. Incorrect installation can deactivate electrical safety features without this being apparent to a lay person.

- Do not open the housing of the device.
- The device should only be installed and put into operation by a certified electrician.
- Ensure that the device can be enabled.
- Secure the line feed with a B6 or C6 line protection switch

### Instructions for the secure operation of KNX/DALI Gateways

- Do not use the device to control safety-related applications (e.g. emergency lighting).
- Install the device in a protected area (enclosed control cabinet).
- Only operate the device in a protected network environment and do not allow direct access from the Internet.
- Set up a separate IP network with its own hardware for KNX communication.
- Protect the device by assigning a BCU key in the ETS.
- Secure remote access to the device via an additional VPN connection. A virtual private network (VPN) establishes an encrypted and authorized connection (VPN tunnel) from a remote connection to a network via the internet. This VPN connection enables secure communication protected from eavesdropping between a remote device and the KNX installation.
- If Wi-Fi is used, change the preset SSID of the wireless access point. Encrypt the Wi-Fi using a secure procedure (such as WPA2 at present).
- Document network settings and give them to the building owner/operator or LAN administrator.
- Coordinate the administration of access rights to this KNXnet/IP device in an IP network with the respective IP network administrator.



## NOTICE



### Measures after replacing a device in the KNX/IP network.

When a KNX device is stolen from a network or replaced due to a defect, the BCU key must be reassigned (changed) for all other devices in the network. This change is necessary because it cannot be ruled out that the BCU key, which is located in a protected area, can be read



For more information on KNX security, including, for example, a security check, refer to the "KNX Secure" section on the KNX website (<http://www.knx.org>).

### Notes on the FDSK sticker

- Remove the device from the sealed packaging, scan the FDSK and store.
- Remove all FDSK stickers from the device and then install the device.

This procedure ensures that the FDSK cannot be read from mounted devices.

## NOTICE



If the scanned FDSK is lost, the device can no longer be used (in secure mode) after a master reset.

For devices with secure by default and a lost FDSK, the device can no longer be used after a master reset.

### Note on installation

The device can be used for fixed installations in dry interior spaces, for installation in high-voltage distribution boards with DIN rails EN 60715-TH35 or small casings.



## Connecting the supply voltage





Fig. 7: KNX/DALI Gateway - connection of the supply voltage

Cu	
	0.5...2.5 mm <sup>2</sup>
	2.5 mm <sup>2</sup>





## Connecting KNX




Fig. 8: KNX/DALI Gateway - connection of KNX

## Optional Ethernet connection

It is possible to optionally connect an Ethernet cable (recommended) to achieve a faster download speed.




Fig. 9: KNX/DALI Gateway - Ethernet connection



### Testing KNX 24 V DC type. SELV

This test can be used to check whether the bus connection cable is connected with the correct polarity and whether device is supplied with bus voltage.




Fig. 10: KNX/DALI Gateway - testing KNX 24 V DC type. SELV

Holding the programming button down for more than 20 seconds resets the device to its factory settings.

### Testing the DALI broadcast




Fig. 11: KNX/DALI Gateway - testing the DALI broadcast

### Disposal



The device is considered an electronic device for disposal in accordance with European Directive and may not be disposed of as domestic waste.

- Use only designated channels for disposing the devices.
- Comply with all local and currently applicable laws and regulations.



If a device is defective, contact the local sales office.



## Technical data

Electrical Data	N 141/14	N 141/32
KNX bus voltage	DC 24 V (DC 21...30 V)	
KNX power consumption	5 mA	
<b>Operating voltage</b>		
Nominal value	230 V	
Rated value AC	220 V ... 240 V, 50 - 60 Hz	
Rated value DC	220 V ... 240 V	
Power loss (internal consumption)	1.6 W AC / 1.8 W DC	
Power consumption (at 192 mA load per DALI channel)	6 W	11 W

Inputs/outputs	N 141/14	N 141/32
Power connection	3-pole (earth, N, L)	
DALI interface with DALI-2 certification according to IEC 62386-101 and 103	1	2
DALI power supply per line	approx. DC 18 V, potential-free, short circuit-proof max. current: I <sub>max</sub> = 250 mA max. guaranteed current: I <sub>max</sub> = 192 mA* Connection of an additional DALI power supply not allowed	
Shutdown mechanism	Switch-off waiting time 700 ms Restart waiting time 10 s	
DALI function	DALI Multi-Master Application Controller with integrated bus power supply (no other supply allowed)	
DALI line length for copper at 25 °C	2.5 mm <sup>2</sup> (AWG 14) max. 300 m (328 yd) 1.5 mm <sup>2</sup> (AWG 16) max. 300 m (328 yd) 1.0 mm <sup>2</sup> (AWG 18) max. 224 m (225 yd) The power loop resistance for each connected ECG must not exceed 10 Ohm.	

\* for horizontal installation position with DALI connection at the top, otherwise 150 mA

Network communication	N 141/14	N 141/32
Standard for interfaces	Ethernet	
Internet protocols supported	ARP, ICMP, IGMP, TCP/IP, UDP/IP, DHCP, AutoIP	
KNXnet/IP as per KNX system specification	Core v2, Tunneling v2, Device Management, IP Secure, Secure Ready	



Mechanical data	N 141/14	N 141/32
Housing material	Plastic	
Dimensions	Rail-mounted device in N dimension Width 4 HP (1 HP = 18 mm) Dimensional drawing [► 22]	
Weight (device)	205 g	210 g
Fire load	5 MJ	

Environmental conditions	N 141/14	N 141/32
Environmental category (as per EN 60721-3-3)	Class 3k5	
Ambient temperature in operation	-5 °C...+45 °C (23 °F...113 °F)	
Storage temperature	-20 °C...+70 °C (-4 °F...158 °F)	
Transport temperature	-25 °C...+70 °C (-13 °F...158 °F)	
Relative humidity (non-condensing)	5%...95%	


Protection settings	N 141/14	N 141/32
Degree of pollution (according to IEC 60664-1)	2	
Over-voltage category (according to IEC 60664-1)	III	
Housing protection class (according to EN 60529)	IP20	
Electrical safety, KNX (SELV)	yes	
Electrical safety, device fulfills	EN 50428	
EMC requirements, device complies with	EN 50428	
Certification logos	KNX, EAC, RCM, WEEE, China-RoHS, DALI-2, UKCA	
CE mark	yes	

Reliability	N 141/14	N 141/32
Failure rate (at 40°C)	834 fit	976 fit











## Compliance information

### **European Union conformity**

Contact for regulatory topics: (EU) Siemens AG, Berliner Ring 23, DE-76437 Rastatt

### **United Kingdom conformity assessed**

Contact for regulatory topics: (GB) Siemens plc, Sir William Siemens House, Princess Road, Manchester, M20 2U



gépész/bolt gépész/bolt gépész/bolt  
gépész/bolt gépész/bolt gépész/bolt  
gépész/bolt gépész/bolt gépész/bolt  
gépész/bolt gépész/bolt gépész/bolt

Issued by  
Siemens Switzerland Ltd  
Smart Infrastructure  
Global Headquarters  
Theilerstrasse 1a  
CH-6300 Zug  
+41 58 724 2424  
[www.siemens.com/buildingtechnologies](http://www.siemens.com/buildingtechnologies)

© Siemens 2024  
Technical specifications and availability subject to change without notice.

---

Document ID    A6V12547710\_en--\_a  
Edition        2025-04-30